

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-1341:103 Page 1 of 1

CATEGORY: Voice Communication Systems Control Units

LISTEE: Safetech International Inc., 13402 W. 92nd Lenexa, KS 66215
Contact: Gaylen Davenport (913) 894-4855

DESIGN: Model SENS-25 audio adjunct system. The unit is intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input: 24-32 VAC/DC, Standby: 24 VDC, 7 Ah Battery

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice communication/audio adjunct system for use with a separately listed electrically compatible fire alarm speakers and fire alarm control units.

XLF: 6911-1446:100

12-13-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager